



April 4<sup>th</sup>, 2024

### Declaration of operational compliance between Tigo's TS4 Module Platform and Fimer inverters

Tigo and Fimer are pleased to announce that the following Fimer Inverters:

**Single Phase Inverters**

UNO-DM-1.2/2.0/3.0-TL-PLUS-Q  
UNO-DM-3.3/3.6/4.0/4.6/5.0-TL-PLUS-Q  
UNO-DM-6.0-TL-PLUS-Q  
UNO-DM-6.0-TL-PLUS-US-Q

**Energy Storage Inverters**

REACT2-UNO-3.6/5.0-TL

**Three Phase Inverters**

TRIO-5.8/7.5/8.5-TL-OUTD  
TRIO-20.0/27.6-TL-OUTD  
PVI-10.0/12.5-TL-OUTD  
PVS-10/12.5/15-TL  
PVS-20/30/33-TL  
PVS-50/60-TL  
PVS-100/120-TL

are operationally compliant with the following TS4 products from Tigo:

TS4-A-O, -S

TS4-X-O, -S

Tigo and Fimer have conducted testing and validated the effective performance of the systems together within standard testing environments. Warranties from Fimer and Tigo will remain valid if the design, installation, and operation requirements are followed for each product.

Contact Tigo Support with any questions regarding Tigo TS4 Module Platform equipment: [support@tigoenergy.com](mailto:support@tigoenergy.com) or (408)-402-0802

**Tigo Energy, Inc.**

655 Campbell Technology Pkwy Ste 150  
Campbell, CA 95008

**FIMER**

Fimer S.p.A.  
Via S. Giorgio 642  
52028 Terranuova B.ni (AR) Italy

Namjun Kim, Project Manager

Print Name and Title

04/05/2024

Signature and Date

Giovanni Manchia, Chief Technology Officer

Print Name and Title

, 04/05/2024

Signature and Date